

Č. Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

1. Identifikace výrobku:
AK-100 Hlídač průtoku
2. Typ výrobku:
Hlídač průtoku
3. Zamýšlené použití výrobku:
Tento typ spínače má 1 kontakt, který je řízen průtokem. Používá se pro bezpečnostní zařízení nebo pro signalizaci průtoku.
4. 5. Výrobce:
Hacı Ayvaz End. Mamuller san. Ve Tic. A.Ş.
Atatürk San. Bolg. Mustafa Inan cad. No. 44
TR-34555 Hadimkoy/Istanbul
Distributor/dodavatel:
EJMAFLEX s.r.o.
Nádražní 1160, 684 01 Slavkov u Brna, ČR
6. Systém posuzování a ověřování stálosti vlastností:
Systém 4 dle Nařízení Evropského parlamentu a Rady (EU) č. 305/2011, Přílohy V čl. 1.5 odst. A
7. 8. Subjekty zapojené do posuzování a ověřování stálosti vlastností dle harmonizovaných norem:
TÜV SÜD DEUTSCHLAND BAU UND BETRIEB GmbH (0036)
Číslo certifikátu: Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
Test report: P-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
9. Deklarované vlastnosti:


Základní charakteristika	Vlastnost	Harmonizované technické specifikace
Jmenovitý tlak PN	PN16	
Maximální povolená teplota	90 °C	
Tlaková zkouška na	24 BAR	
Listy	Nerez	EN 12516-1

10. Vlastnosti výrobku uvedené v bodě 1 a 2 jsou ve shodě s vlastnostmi uvedenými v bodě 9. Toto prohlášení o vlastnostech se vydává na výhradní zodpovědnost výrobce uvedeného v bodě 4.

Podepsán za výrobce v Istanbulu/Turecko dne 4.7.2013 : M. Erkan Altug – Q.A. Manager

Za správnost překladu:

Ing. Jaroslav Sláma, jednatel



Ve Slavkově u Brna 9.7.2013

.....

Prohlášení o vlastnostech v souladu s EN L 88/38 Věstník EU 4.4.2011/Příloha III

DECLARATION of PERFORMANCE

No. Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

1. Unique identification code of the product type:

AK-100 Flow Switch

2. Type:

Flow Switch

3. Intended use:

This type switch have 1 contact; And this contact is controlled by flows. It is used for security equipment or warning flow existences.

- 4,5. Producer:

Haci Ayvaz End. Mamuller San. Ve Tic A.Ş.
Atatürk San. Bolg. Mustafa Inan cad. No.44
TR-34555 Hadimkoy/Istanbul

6. Systems of assessment and verification of constancy of performance of the construction product as set:

System 4 acc. to the Regulation (EU) No. 305/2011 Annex V. Article 1.5. paragraph a.

- 7,8. Name and identification number of the notified body and Technical Assessment Body who took part at the verification:

TÜV SÜD DEUTSCHLAND BAU UND BETRIEB GmbH (0036)
Certificate No: Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
Test report No: P-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

9. Declared Performance

Basic Essential Characteristics	Performance	Harmonised Technical Specification
Pressure Nominal	16 BAR	
Max. Allowable Temperature	90 °C	
Test Pressure	24 BAR	
Plates	Stainless Steel	EN 12516-1

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by;

M. Erkan Altuğ – Q.A. Manager



İstanbul/Turkey

04.07.2013

DoP in accordance with EN L 88/38 Official of the European Union 4.4.2011 / ANNEX III