

Č. Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

1. Identifikace výrobku:
BDV Redukční ventil
2. Typ výrobku:
Redukční ventil
3. Zamýšlené použití výrobku:
Redukční ventil se používá k vyrovnání, redukci systémového tlaku z vyššího na nižší. Umísťují se zpravidla na vstup budov nebo sídel, v průmyslu na vstupu do zařízení.
4. 5. Výrobce:
Hacı Ayvaz End. Mamuller san. Ve Tic. A.S.
Atatürk San. Bolg. Mustafa Inan cad. No. 44
TR-34555 Hadimkoy/Istanbul
Distributor/dodavatel:
EJMAFLEX s.r.o.
Nádražní 1160, 684 01 Slavkov u Brna, ČR
6. Systém posuzování a ověřování stálosti vlastností:
Systém 4 dle Nařízení Evropského parlamentu a Rady (EU) č. 305/2011, Přílohy V čl. 1.5 odst. A
7. 8. Subjekty zapojené do posuzování a ověřování stálosti vlastností dle harmonizovaných norem:
TÜV SÜD DEUTSCHLAND BAU UND BETRIEB GmbH (0036)
Číslo certifikátu: Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
Test report: P-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
9. Deklarované vlastnosti:


Základní charakteristika	Vlastnost	Harmonizované technické specifikace
Velikost	1/2" – 3/4" – 1" DN15-20-25	EN ISO 228-1 nebo NPT EN 1092-2
Jmenovitý tlak PN	PN25	
Maximální dovolená teplota	210°C	
Tlaková zkouška na	37,5 BAR	
Materiál tělesa	Litina GGG 40.3	EN16079
Materiál filtru	AISI 316	EN12516-1

10. Vlastnosti výrobku uvedené v bodě 1 a 2 jsou ve shodě s vlastnostmi uvedenými v bodě 9. Toto prohlášení o vlastnostech se vydává na výhradní zodpovědnost výrobce uvedeného v bodě 4.

Podepsán za výrobce v Istanbulu/Turecko dne 4.7.2013 : M. Erkan Altug – Q.A. Manager

Za správnost překladu:

Ing. Jaroslav Sláma, jednatel



Ve Slavkově u Brna 9.7.2013

.....

Prohlášení o vlastnostech v souladu s EN L 88/38 Věstník EU 4.4.2011/Příloha III

DECLARATION of PERFORMANCE

No. Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

1. Unique identification code of the product type:

BDV Pressure Reducing Valve

2. Type:

Pressure Reducing Valve

3. Intended use:

Pressure reducing valves are used to balance the system pressure; they are placed at the entrance of the buildings or residences

- 4.5. Producer:

Haci Ayvaz End. Mamuller San. Ve Tic A.Ş.
Atatürk San. Bolg. Mustafa Inan cad. No.44
TR-34555 Hadimkoy/Istanbul

6. Systems of assessment and verification of constancy of performance of the construction product as set:

System 4 acc. to the Regulation (EU) No. 305/2011 Annex V. Article 1.5. paragraph a.

- 7.8. Name and identification number of the notified body and Technical Assessment Body who took part at the verification:

TÜV SÜD DEUTSCHLAND BAU UND BETRIEB GmbH (0036)
Certificate No: Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
Test report No: P-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

9. Declared Performance

Basic Essential Characteristics	Performance	Harmonized Technical Specification
Size	1/2"-3/4"-1" DN15-20-25	EN ISO 228-1 or NPT EN 1092-2
Pressure Nominal	25 BAR	
Max. Allowable Temperature	210°C	
Test Pressure	37.5 BAR	
Body Material	Cast Iron GGG 40.3	EN 16079
Strainer Material	AISI 316	EN 12516-1

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by;

M. Erkan Altuğ – Q.A. Manager



İstanbul/Turkey

04.07.2013

DoP in accordance with EN L 88/38 Official of the European Union 4.4.2011 / ANNEX III