

**DECLARATION OF CONFORMITY**  
**DIRECTIVE 97/23/EC (PRESSURE EQUIPMENT DIRECTIVE)**

*The model of this Declaration is conforming to the norm EN 45014*

The company: **HACI AYVAZ END. MAM. SAN. ve TİC. A.Ş.**

Address: **Atatürk S.B.Mustafa İnan Cad. No: 36**  
**34555 Hadımköy - Istanbul/TÜRKİYE**

Declares that,

**DUAL FLAP WAFER CHECK VALVE**

**Type:** **CV 20**

**Size:** **DN50-DN300 / PN 16**  
**DN350-DN600 / PN 10**

**Description:** CV20 PN16 DN50, CV20 PN16 DN65,  
CV20 PN16 DN80, CV20 PN16 DN100,  
CV20 PN16 DN125, CV20 PN16 DN150,  
CV20 PN16 DN200, CV20 PN16 DN250,  
CV20 PN16 DN300, CV20 PN10 DN350,  
CV20 PN10 DN400, CV20 PN10 DN450,  
CV20 PN10 DN500, CV20 PN10 DN600

Other technical standards and specifications used

Nominal Pressure: **1 Bar**  
Module: **DN50 (I,A),DN65-200 (II,A1)**  
Category: **SEP**

Body Material Cast Iron GG 25, Disc Material Stainless Steel AISI 316,  
Resilient Seat Material EPDM.

**Complies with**

**Pressure Equipment Directive 97/23/EC – SEP,I,A,II,A1**

TÜV SÜD Industrie Service GmbH (0036)  
Certificate No: DGR-0036-QS-962-11

Name: **Buğra KOZANLI**  
Position: **Quality Control & Assurance Chief**  
Place / date: **Istanbul-TURKEY / 01.05.2011**  
Signature:

