

Č. Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

1. Identifikace výrobku:
CV-10/S1 Mezipřírubový zpětný ventil
2. Typ výrobku:
Mezipřírubový zpětný ventil
3. Zamýšlené použití výrobku:
Zpětné ventily se běžně používají jako armatury, které mohou být použity pro kapaliny, plyny a páry.
4. 5. Výrobce:
Hacı Ayvaz End. Mamuller san. Ve Tic. A.S.
Atatürk San. Bolg. Mustafa Inan cad. No. 44
TR-34555 Hadimkoy/Istanbul
Distributor/dodavatel:
EJMAFLEX s.r.o.
Nádražní 1160, 684 01 Slavkov u Brna, ČR
6. Systém posuzování a ověřování stálosti vlastností:
Systém 4 dle Nařízení Evropského parlamentu a Rady (EU) č. 305/2011, Přílohy V čl. 1.5 odst. A
7. 8. Subjekty zapojené do posuzování a ověřování stálosti vlastností dle harmonizovaných norem:
TÜV SÜD DEUTSCHLAND BAU UND BETRIEB GmbH (0036)
Číslo certifikátu: Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
Test report: P-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
9. Deklarované vlastnosti:


Základní charakteristika	Vlastnost	Harmonizované technické specifikace
Velikost	DN15 až DN100	EN 1074-3
Jmenovitý tlak PN	PN40	EN 1074-3
Maximální dovolená teplota	300 °C	
Tlaková zkouška na	60 BAR	EN 1074-1
Materiál tělesa	Přesný odlitek AISI 304	EN 12516-1
Materiál disku	Nerez AISI 316	EN 12516-1

10. Vlastnosti výrobku uvedené v bodě 1 a 2 jsou ve shodě s vlastnostmi uvedenými v bodě 9. Toto prohlášení o vlastnostech se vydává na výhradní zodpovědnost výrobce uvedeného v bodě 4.

Podepsán za výrobce v Istanbulu/Turecko dne 4.7.2013 : M. Erkan Altug – Q.A. Manager

Za správnost překladu:

Ing. Jaroslav Sláma, jednatel



Ve Slavkově u Brna 9.7.2013

Prohlášení o vlastnostech v souladu s EN L 88/38 Věstník EU 4.4.2011/Příloha III

DECLARATION of PERFORMANCE

No. Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

1. Unique identification code of the product type:

CV 10/S1 Disco Check Valve

2. Type:

Disco Check Valve

3. Intended use:

Check valves are commonly used armatures that can be applied for liquid, gaseous and steam applications.

- 4.5. Producer:

Haci Ayvaz End. Mamuller San. Ve Tic A.Ş.
Atatürk San. Bolg. Mustafa Inan cad. No.44
TR-34555 Hadimkoy/Istanbul

6. Systems of assessment and verification of constancy of performance of the construction product as set:

System 4 acc. to the Regulation (EU) No. 305/2011 Annex V. Article 1.5. paragraph a.

- 7.8. Name and identification number of the notified body and Technical Assessment Body who took part at the verification:

TÜV SÜD DEUTSCHLAND BAU UND BETRIEB GmbH (0036)
Certificate No: Z-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev
Test report No: P-IS-TGK-IST-12-08-121000124-001-11-B-00023Rev

9. Declared Performance

Basic Essential Characteristics	Performance	Harmonized Technical Specification
Size	DN15 to DN100	EN 1074-3
Pressure Nominal	40 BAR	EN 1074-3
Max. Allowable Temperature	300°C	
Test Pressure	60 BAR	EN 1074-1
Body Material	Investment Casting AISI 304	EN 12516-1
Disc Material	Stainless Steel AISI 316	EN 12516-1

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by;

M. Erkan Altuğ – Q.A. Manager



İstanbul/Turkey

04.07.2013

DoP in accordance with EN L 88/38 Official of the European Union 4.4.2011 / ANNEX III